

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1077Dated: 18/3/26


It is certified that an inspection team headed by Shri CA Kalele Chief Chemist
(Name of Officers with designation) from State Research Laboratory, PHED Bhopal
PHED inspected the Sardar Patel Public School, Ward no. 53, Hoshangabad Road, Misrod, Bhopal, MP on
16/3/26 and on the basis of Water Test Report (Attached) bearing no. 1077 dated
18/3/26 of SRL, PHED, Bhopal (PHED Lab)

certified that the Sardar Patel Public School, Ward no. 53, Hoshangabad Road, Misrod, Bhopal, MP has safe
drinking water facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/
State/ U.T. Govt.

This certificate is valid till one year

Signature with seal

:-



Name

:-

CHUDAMANI KALELE

Chief Chemist

Designation

:-

State Research Laboratory


P.H. Eng. Dept. Bhopal

Name & address of the office/Department: - _____

To,
Sardar Patel Public School,
Ward no. 53, Hoshangabad Road, Misrod, Bhopal, MP
(Name and address of the institution)



PRINCIPAL
SARDAR PATEL PUBLIC SCHOOL
BHOPAL


PRINCIPAL
Sardar Patel Public School
Misrod, Bhopal

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Test Report

Nature of sample :- Drinking Water Sample / Others	Not sampled by State Research Lab	Unique Identification No.	-
To, SARDAR PATEL PUBLIC SCHOOL MISROD BHOPAL	Sender's letter no.	-	Sender's letter Date
	SRL Ref. No	-	SRL receipt date
	Date of analysis started	17/03/26	Date of analysis completed
	Quantity Of sample	Ok	

Sample details

No.	Particulars of Samples
1.	TAP WATER SAMPLE

RESULTS

Field..	Testing	Discipline..Chemical	Group..Water		Sub. Group..Drinking Water				
No.	Characteristics/ Unit	test methods	BIS -10500:2012 Reaffirmed in Sep 2022		Results				
			Desirable Limit	Permissible Limit	1	2	3	4	5
1	2	3	4	5	1	2	3	4	5
1	Colour in Hazen scale	IS 3025 part 4 2021	5	15	BDL	-	-	-	-
2	Taste	IS 3025 part 8 1984	Agreeable	unagreeable	Agreeable	-	-	-	-
3	Odour	IS 3025 part 5 2018	Agreeable	unagreeable	Agreeable	-	-	-	-
5	Chloride as Cl mg/l	APHA 24 th edition, 4500 Cl-B	250	1000	15	-	-	-	-
6	Total Alkalinity as CaCO ₃ mg/l	APHA 24 th edition, 2320 B	200	600	66	-	-	-	-
7	Calcium as Ca ⁺⁺ mg/l	APHA 24 th edition, 3500 Ca-B	75	200	44	-	-	-	-
8	Magnesium as Mg ⁺⁺ mg/l	APHA 24 th edition, 3500 Mg-	30	100	28.0	-	-	-	-
9	pH pH Value at 25°C	APHA 24 th edition 4500-H + B	6.5 to 8.5	6.5 to 8.5	7.30	-	-	-	-
10	Turbidity in NTU	APHA 24 th edition, 2130 B	1.0	5.0	1.0	-	-	-	-
11	Total hardness as CaCO ₃ mg/l	APHA 24 th edition, 2340 C	200	600	74	-	-	-	-
12	TDS By meter mg/l	APHA 24 th edition, 2510 B	500	2000	120	-	-	-	-
13	Free Residual Chlorine	IS 3025 part 26	1.0	0.2	NIL	-	-	-	-
14	Ecoli	APHA 24 th edition, 9223 B	NIL		NIL	-	-	-	-
15	Total coliform per 100 ml	APHA 24 th edition, 9223 B	NIL for treated water and water in distribution system		NIL	-	-	-	-

1. This report should not be produced partly or full without approval of signatory authority for legal purposes.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
3. The results refer only to tested samples and parameters tested
4. Samples will be stored for a period of 16 days from the date of issue of report.
5. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Reviewed by

(Chudamani Kalele)
Chief Chemist
STATE RESEARCH LABORATORY
P. H. E. DEPARTMENT BHOPAL

Issue No. 1077 /S.R.L./PHED/BPL /2026 Issue Date 18/3/26

1/1
End of Report

CHAIRMAN
SARDAR PATEL PUBLIC SCHOOL
BHOPAL

PRINCIPAL
Sardar Patel Public School
Misrod, Bhopal